



County of Riverside  
DEPARTMENT OF ENVIRONMENTAL HEALTH

www.rivcoeh.org

SUPPLEMENTAL REPORT TO SAN. FORM # 2616/011/459 DATE 8-24-2019  
SUBJECT Vons # 2660 - Deli PERMIT NO. 08441  
ADDRESS 38995 Sky Canyon Dr., Murrieta CA 92563 DISTRICT 43  
INSPECTOR L. La

REMARKS:

- This is a follow up inspection to evaluate a closed facility, Vons # 2660 - Deli, due to grease interceptor failed and overflowed with floor sinks/drains within this deli clogged on 8/23/2019.
- Invoices of grease interceptor pumped, floor drains/sinks in the deli unclogged per professional plumber and proper high pressure and sanitized cleaning of the floor inside Deli and parking lot emailed to inspector. All above clean-up conducted by end of day on 8/23/2018 per invoices.
- At this re-inspection, the following were observed:
  - ① grease interceptor clean & pumped. Parking lot concrete clean without overflow
  - ② all floor drains & sinks clean and clear of debris - No clogged of floor sink/drains observed.
  - ③ floors + walls in deli properly clean and sanitized.
  - ④ all equipment and utensils clean and sanitized.
- Deli is approved to open and operate as usual.
- Invoice of grease interceptor, plumber repaired and cleaning attached with this report.
- Manager, April Lay present with this re-inspection.

RECEIVED BY:

April Lay

Distribution: WHITE-Office; CANARY-Owner